

1. Document Control

Company Name	Galvin Engineering	Address	410 Victoria Road
Client Name	Anna Rees	City/Suburb	Malaga
E-mail	Sales@galvinengineering.com.au	State/Province	Western Australia
Phone	+61 8 9338 2344	Postal/Zip Code	6090
ABN	78 008 719 382	Country	Australia

Document Number: GLV-24-3-REP-IFO Spira-A-1

Date: 11/12/2025

Sample tested:	Ifo Spira Toilet Pan
Code:	62610009
Test Summary	

This document is confirmation that the above samples have been tested at PROVE standards and engineering.

The toilet pan was mounted to a solid frame using the supplied mounting bracket and a 1100N Load was applied at a central point on the cistern from the front, rear, left and right sides. Testing was to confirm that the cistern was able to withstand the forces typical of a toilet backrest to AS 1428.1

The Sample tested withstood the loading conditions without deformation or breakage, for full details of testing and results please read report: GLV-24-3-REP-IFO Spira-1