

TM-SNKXD

Product Installation Guidelines & Scope of Use

Version 4.3, 5 May 2025, Page 1 of 6 Document No.: TM-SNKX

TM-SNKX

CliniLever[®] SS Lead Safe[™] Sink Mixer

PRODUCT CODES:

- TM-SNKX
- TM-SNKXD

SPECIFICATIONS

- Lead Safe[™] stainless steel construction. *
- Clean hygienic design
- Low maintenance and easy to operate.
- Smooth round designs to facilitate easy cleaning and help reduce dirt and bacteria growth.

3.0

IMPORTANT: All CliniLever[®] Taps are tested in accordance with AS 3718 and leave our premises in good working order.

5.0

*Our Lead Safe™ product range is compliant with the Lead Free Requirements of the NCC 2022 Vol. Three, Clause A5G4(2) and NSF/ANSI 372. ** Any flow controller incorporated in the outlet to be tightened to prevent removal by hand. As Per AS3718.

WARNINGS: Special attention to be paid on notes, photos, images, or drawings of assembly steps marked with the warning symbol.



TECHNICAL DATA

Inlet		1/2" BSP – Female (Flexi-hoses)	
Outlet		Aerator	
Headwork		Ceramic Cartridge	
Working Pressure Range (kPa)	Min	50	
	Max	500	
Warking Torrespondence (%C)	Min	5	
working Temperature Range (°C)	Max	60	
Nominal Flow Rate (LPM)		3.00 and 4.7	
Construction		Stainless Steel	
Finish		Brushed Stainless Steel	
NOTE: Galvin Engineering continually strive to improve their products. Specifications may change without notice.			



© Galvin Engineering Pty Ltd

DIMENSIONS – TM-SNKXD



INSTALLATION

INSTALLATION COMPLIANCE: Galvin Engineering products must be installed in accordance with these installation instructions and in accordance with AS/NZS 3500, the PCA and your local regulatory requirements. Water and/or electrical supply conditions must also comply to the applicable national and/or state standards. Failing to comply with these provisions shall void the product warranty and may affect the performance of the product.



Version 4.3, 5 May 2025, Page **3** of **6**



Dual-Star Rated Items (WELS)

Due to some state requirements, items are required to be in higher star rating (6-star). Therefore, for some items, two flow regulators are supplied. Primarily, the higher star-rated flow regulator is equipped in the assembly.

Items	Primary Flow Regulator	Alternative Flow regulator
TM-SNKX and TM-SNKXD	6-stars (blue)	5-stars (orange)

REMOVE & INSPECT FLOW REGULATING AERATOR



REMOVE & INSPECT CARTRIDGE







TROUBLESHOOTING

PROBLEM	CAUSE	RECTIFICATION	
Tap is leaking	Headworks are worn or damaged	Remove and inspect the headworks, remove debris and/or replace parts if damaged	
	Tap incorrectly installed	Follow the installation steps above when fitting the tap.	
Tap has inconsistent flow	Blocked flow regulator	Follow the instructions above to remove flow regulator from the body and check for debris. Install an inline strainer to stop further blockages.	
Tap moves on basin	Insufficiently tightened	Follow the steps above in relation to tightening the installation.	
Water temperature is opposite to the handle markings	Inlet hoses connected incorrectly	Connect the inlet hoses to the correct inlets as shown above.	

WARRANTY

Galvin Engineering products are covered under our Manufacturer's Warranty. Galvin Engineering products must be installed in accordance with the installation instructions and in accordance with AS 3500 and NCC Volume Three, relevant Australian Standards and local authorities applicable to product being installed. Water and electrical supply conditions must also comply to the applicable national and/or state standards, failing to comply with these provisions may void the product warranty and affect performance of the product.

Please visit www.galvinengineering.com.au to view the full warranty, our Installation Compliance and Maintenance & Cleaning information as well as any other additional information.

